



LETTER OF COMPLIANCE

To all customers,

ArcelorMittal Produits Tubulaires Montréal Inc.
Arcelormittal Tubular Products Montreal inc.

certifies that all pipe sold according to the specifications mentioned in the table hereafter are approved under

UL/ULC (File EX-5138)
 FM (approved for Dry and Wet systems)

CERTIFICATE	SCHEDULE	STANDARD	TYPE	GRADE	DIAMETER
FM	10	ASTM A53 or A795	E and F	A	1 1/4 to 6 "
FM	40	ASTM A53 or A795	E and F	A	1 to 4 "
ULC / UL	10	ASTM A795	E	A	2 to 6"
ULC / UL	10	ASTM A795	F	A	1 ,1 1/4 , 1 1/2"
ULC / UL	40	ASTM A53	F	A	1/2 to 4"

Raphaël Ciccariello,eng.
 Chief Metallurgist ,Pipe and Quality Assurance
 January 18, 2008

ArcelorMittal Produits Tubulaires Montréal Inc. Tel : +1 514- 762-5200
 Arcelormittal Tubular Products Montreal inc. 1-800- 361-4344
 5870, rue St-Patrick Fax : +1 514-762-5210
 Montréal, P.Q.
 Canada
 H4E 1B3